



HINGHAM FIRE DEPARTMENT FIRE PREVENTION

**210 Central Street
Hingham, MA 02043**

Lieutenant Christopher DiNapoli
Fire Marshal

June 12, 2020

Members of the Planning Board,

In regards to the proposed project at 19-27 Whiting St the fire dept. offers the following comments;

Commercial property requires a hydrant within 500 feet of the structure measured over approved driving surface not as the crow flies.

Commercial Properties require the following prior to receiving occupancy sign off from Fire Dept.

Knox Box key box(s) at a location(s) on the building approved by the Fire Dept.

Knox Power Shunt switch location to be coordinated with Fire Dept. and Electrical Inspector

Red Beacon over the Knox Box(s)

Information on the Knox products is available at knoxbox.com search for Hingham.

These are only comments at this time as the project develops we may offer further comments.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham