

**From:** [Pat Brennan](#)  
**To:** [Wentworth, Emily](#)  
**Cc:** [Susan Murphy](#)  
**Subject:** Re: Submission from Kirk Shilts  
**Date:** Wednesday, February 12, 2020 9:36:26 AM  
**Attachments:** [Title 5 Excerpts.pdf](#)

---

Emily & Susan,

Please see the attached excerpts from Title 5. The nitrogen loading limitations are not imposed on a "facility," they are imposed on a "system" - see 15.214. The definition of a system is limited to the piping, tanks, distribution systems and soil absorption systems - see definitions. None of these system components are located within the Zone II on the property. The proposed septic systems shown on the 302-304 Whiting Street plans are in compliance with 310 CMR 15.214.

Please let me know if you have any questions.

Pat

Patrick G. Brennan, P.E.  
Amory Engineers, P.C.  
25 Depot Street, PO Box 1768  
Duxbury, MA 02331  
p 781-934-0178  
c 781-799-0279  
[pbrennan@amoryengineers.com](mailto:pbrennan@amoryengineers.com)  
Website: [www.amoryengineers.com](http://www.amoryengineers.com)

On Wed, Feb 12, 2020 at 9:14 AM Wentworth, Emily <[wentworthe@hingham-ma.gov](mailto:wentworthe@hingham-ma.gov)> wrote:

FYI



Town of Hingham Massachusetts

**Emily Wentworth**

Senior Planner: Zoning/Special Projects  
Town of Hingham  
210 Central Street  
Hingham, MA 02043  
Voice: (781) 741-1494  
Fax: (781) 740-0239  
[wentworthe@hingham-ma.gov](mailto:wentworthe@hingham-ma.gov)  
[www.hingham-ma.gov](http://www.hingham-ma.gov)

---

