



## **HINGHAM FIRE DEPARTMENT FIRE PREVENTION**

**210 Central Street  
Hingham, MA 02043**

Lieutenant Christopher DiNapoli  
Fire Marshal

January 6, 2020

Members of the Zoning Board,

The fire dept. has reviewed the proposed project at 302/304 Whiting St and offers the following comments;

- 1) Driveway must be a maintained 20 foot wide paved access not to exceed 150' without an approved turnaround
- 2) Hydrant Bylaw Residential:  
Hydrant Bylaw Article 32 Section 9: For residential properties a hydrant must be located within 800 feet of the new structure. This is measured over approved drivable service not as the crow flies.

These are our only comments at this time as the project develops we may offer further comments.

Respectfully,

Lieutenant Chris DiNapoli  
Fire Marshal, Town of Hingham