


James Engineering, Inc.
125 Great Rock Road, Hanover, MA 02339
Tel; 781-878-1795 email: jameseng125_gary@msn.com



July 23, 2021

Ms. Emily Wentworth, Senior Planner, Zoning/Special Projects
Planning Board
Town of Hingham
210 Central Street
Hingham, MA 02043

Re: 2 Annick Drive, Site Plan Review

Ms. Wentworth and Members of the Planning Board;

In response to the review letter provided to the Planning Board by Amory Engineers, PC dated July 21, 2021, attached for your review and approval are 6 sets of the revised plans for the above noted site. The plans have been revised in response to the comments and I have also made some additional corrections requested by the Board of Health. Specifically, they are;

1. A Zoning Table has been added to the Utility and Layout Sheet (Sheet 5 of 8)
2. An Erosion Control sheet (Sheet 7 of 8) with details and notes has been added to the set.
3. The elevations and final layout of the roof drain system and leaching pits have been corrected and relocated in accordance with the comments and to accommodate the septic reserve area.
4. A septic reserve area is now shown on the drawing.
5. Sheet 3 of 8 of the drawing set has been renamed to "SUBDIVISION DESIGN" rather than approved design to avoid confusion. In addition, notes have been added to sheet 4 of 8 to help identify the purpose of the plan.

Thank you for this opportunity to respond. If you have any further question or comments regarding the submission, please do not hesitate to contact me. I look forward to speaking with the Board to discuss this further.

Very truly yours,

Gary D. James, P.E.