

From: [Sylvester, Randy](#)
To: [Wentworth, Emily](#)
Cc: [Silveira, Michael](#)
Subject: 261 Gardner Street Comments
Date: Monday, October 24, 2022 2:06:09 PM

Emily,

I have looked at the plans for the 261 Gardner Street subdivision and would strongly recommend that all driveways (existing and proposed) be tied into the proposed subdivision road. This would be safer to all involved in the area due to the fewer curb cuts in the area, especially in the winter.

Also, the DPW does not maintain any sub-surface drainage systems. Therefore, I would not support the Town taking any road or allowing a sub-surface system into the Town's drainage system, which has been proposed at 261 Gardner Street.

Thanks,
Randy



Town of Hingham Massachusetts

Randy Sylvester

DPW Superintendent
Department of Public Works
25 Bare Cove Park Drive
Hingham, MA 02043
Office: (781) 741-1430
Fax: (781) 741-1432
sylvesterr@hingham-ma.gov
www.hingham-ma.gov
