



HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043

Lieutenant Christopher DiNapoli
Fire Marshal

March 19, 2018

Members of the Planning Board

RE: Comments and Drawings Dated March 9, 2018 for River Stone

I have reviewed the latest plans and comments that were submitted to your Board dated March 9, 2018. I offer the following comments regarding what I am reading and seeing.

Page 6 Comment 15: It appears the roadway now goes even further over the proposed septic area. MEG acknowledges the concerns with loading from the weight of apparatus yet they have not provided any documentation to show that it will be supported appropriately.

Plans TT-1: They have now added a roundabout and it appears by their own engineered drawings that the apparatus cannot make it through the design. I would request that either the roundabout be removed or the roadway be constructed so as there is 30 feet of paved driving service around the entire roundabout. This is in my opinion the only way to ensure proper flow of the apparatus through this design. It also appears there are still portions of the design that do not allow for free turning of the apparatus on paved roadway.

Should you have any questions regarding this please do not hesitate to contact me.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham

