



**TOWN OF HINGHAM**  
**BOARD OF HEALTH**  
210 Central Street, Hingham, MA 02043-2762  
(781) 741-1466 Fax (781) 740-0239

December 17, 2019

Emily Wentworth  
Senior Planner  
210 Central St  
Hingham, MA 02043



Re: 302-304 Whiting Street, Hingham MA

I have reviewed the plans labeled *Proposed Subsurface Disposal System 302 Whiting Street, Hingham, MA dated November 24, 2019*. This 40B development will need relief from the Board of Health Supplementary Rules and Regulations. I have listed the regulations that they will need waivers with comments. This is not a complete list but those that have a concern.

1. IV.9: There must be two percs in the primary and two percs in the reserve within 2 years.
2. A water supply commitment letter
3. V.5: Distance from the SDS to the wetland must be 100 ft.
4. VI.8: 110 gallons per day per 12,500 sq. ft.
5. VI.6: Distance from the SDS to a potable well must be 250 ft.

Please let me know if you have any questions.

Susan Sarni, MPH  
Executive Health Officer