



HINGHAM FIRE DEPARTMENT FIRE PREVENTION

210 Central Street
Hingham, MA 02043

Lieutenant Christopher DiNapoli
Fire Marshal

February 8, 2018

To: Zoning Board of Appeals

Re: River Stone Proposed Drawings Dated February 2, 2018



Board Members,

The revised plans showing truck turning radiuses for the fire dept. apparatus. It appears the turning radiuses are not sufficient to allow our vehicles free flow through the proposed development. The fire apparatus must be able to remain on the approved paved surface for all turns. It may not go off over a sidewalk or lawn area.

Respectfully,

Lieutenant Chris DiNapoli
Fire Marshal, Town of Hingham